

Garrett County Department of Public Works

Roads Division
Public Service Center
 2008 Maryland Highway, Suite 3
 Mt. Lake Park, MD 21550
 Phone (301) 334-7488
 Fax (301) 334-7489



Utilities Division
Public Service Center
 2008 Maryland Highway, Suite 2
 Mt. Lake Park, MD 21550
 Phone (301) 334-6983
 Fax (301) 334-6984

TELEPHONE REPORT OF SEWAGE OVERFLOW

Date and Time of Report:	4/1/18 11:51 am	
The date and time when the overflow began and stopped or, if not stopped, the date and time the overflow is expected to be stopped:	Began 3/31/18 @ 10 ¹⁵ am, Stopped 3/31/18 @ 12 ¹⁵ pm	
Whether the overflow is from a combined sewer system (CSO), a separate sanitary sewer system (SSO), or a treatment plant bypass:	Sanitary Sewer Overflow	
The location of the overflow, including latitude and longitude if reasonably available, Maryland Grid Coordinates or nearest street and intersection, city or town, zip code:	Near 2404 Mayhew Inn Rd. Oakland MD 21550	
The name of the owner, operator and telephone number of the sanitary sewer system or treatment plant. (Be sure to include the treatment plant associated with this collection system)	Garrett County Dept. of Public Works Utilities Division. (301) 334-6983 Deep Creek Lake Collections	
The cause or suspected cause of the overflow:	Failed Air Release valve	
The name of the receiving water, if applicable including storm drains, side ditches, etc.	Deep Creek Lake	
The volume discharged based on actual measurement or as an estimate using best professional judgment:	estimated 4,500 gallon	
Is the receiving water designated as shellfish waters or for a public drinking water supply:	<input checked="" type="radio"/> no yes	<input checked="" type="radio"/> NO
	Drinking Water	Shellfish
A description of the combined sewer system, separate sanitary sewer system or treatment plant component from which the overflow was released, such as manhole, crack in pipe, pumping station wet well or constructed overflow pipe:	Air release valve on main line failed open overflowing Air release vault into ditch along Mayhew Inn Rd. then seaked into ground	
A detailed description of visual observations and preliminary assessment of the overflow's actual or potential impact upon waters of the State:	no visual overflow into lake, but adsorbed into ground above lake	
The steps taken or planned to reduce, eliminate, and prevent recurrence of the overflow and a time schedule for completion of the steps:	Air Release is turned off, Scheduled for replacement 4/2/18	
Measures taken or planned to mitigate the adverse impact of the overflow and a time schedule for implementation of the measures:	Spill area was cleaned with vacuum truck and lime stabilized immediately after spill was stopped	
Whether the public and the local Health Department have been notified, who performed the notification, the media used, and the content of the message.	Steve Sherrard from Health Dept. was on site. Spill area and lake were posted and sampling began.	
Name, title and telephone number of the person reporting the overflow:	John Miller / Superintendent (301) 501-1109	

Todd Tracey received call 4/1/18 @ 11⁵¹ am