

Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550
 Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcounty.org

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett		
Is this a combined sewer overflow (CSO)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)		
When did the Overflow Occur	DATE: 8/1/17	TIME: 3:37	AM/PM: <input checked="" type="radio"/>
Is the Overflow Ongoing or has it been repaired	ONGOING <input type="radio"/> REPAIRED <input checked="" type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: 4 hrs	
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	136 Quarry Road (south side of property near existing fire Hydrant along right side of Quarry Rd.)		
Cause of the Overflow - Get as much information as possible.	Cracked 1/2 pvc sewer main @ intersection of 6" water supply line to Fire Hydrant.		
What has been done to correct the Cause of the Overflow	Installed 1/2" Valve, shut off flow, repaired 1/2" pvc sewer main.		
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES) Deep Creek Lake	
Has/will the public be notified? If yes, how?	No / Per Health Dept.		
Has/will the affected water body be posted as being contaminated?	No / Per Health Dept.		
Estimated Quantity of the Overflow in GALLONS	1,500 gallon		
What type of Clean-up or other mitigation is being performed or scheduled to be performed	Heavy Rain .8" in an hour washed ditches clean before clean up could take place. Rained as repairs were being completed.		
Name of the Person Reporting the Overflow	NAME: John M.C. Miller TITLE: Superintendent	PHONE: (301) 501-1109	
Name and type of Facility	FACILITY NAME: DeepCreek Lake	TYPE OF FACILITY: Collections	
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN 5 CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)		
Name of Staff Receiving Report	Kathy Mohan		
Date and Time of Report	DATE: 8/2/17	TIME: 12:23 AM <input checked="" type="radio"/>	
Name of Staff Report was referred to for follow-up			
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; inspector		

Met with Steve Sherrard Garrett Co. Health Dept. on site @ 9⁰⁰am 8/2/17