

Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550
 Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcountry.org

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett	
Is this a combined sewer overflow (CSO)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	
When did the Overflow Occur	DATE: 5/23/15	TIME 7:00 AM <input checked="" type="radio"/> PM
Is the Overflow Ongoing or has it been repaired	ONGOING <input type="radio"/> REPAIRED <input checked="" type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: 5/23/15 @ 7:00 pm - 12:00 am 5/24/15
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	Intersection of driveway @ 106 Lake Forest Drive and Lake Forest Drive	
Cause of the Overflow - Get as much information as possible.	2" Female Fitting on 2" service tap split and ruptured	
What has been done to correct the Cause of the Overflow	line was dug up, corporation stop closed and repairs made. line put Back in service	
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	YES <input checked="" type="radio"/> NO <input type="radio"/> (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES)
Has/will the public be notified? If yes, how?	Deep Creek Lake	
Has/will the affected water body be posted as being contaminated?	Yes, Door to door notification in affected area.	
Estimated Quantity of the Overflow in GALLONS	Yes, Signs posted at each dock in affected area.	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	15,000 gal.	
Name of the Person Reporting the Overflow	Cleaned up with vacuum truck, spill area, roadway & ditches lime stabilized.	
Name and type of Facility	FACILITY NAME: Deep Creek Lake	TYPE OF FACILITY: Collections
Written Follow-up Notice	NAME: John M.C. Miller PHONE: (301) 501-1109	
Name of Staff Receiving Report	TITLE: Superintendent	
Date and Time of Report	DATE: 5/24/15	TIME: 1:50 AM <input checked="" type="radio"/> PM
Name of Staff Report was referred to for follow-up	MDE Person on call Notified Chris Westergard	
Copy Provided to	Followup call @ 2:50 pm Dave Lyons; Bill Lee; Inspection Division Chief; inspector	

Called Steve Sherard Garrett Co. Health Dept. @ 9:14 am, met on sight @ 10:00 am
 At Creston DCI State Park manager @ 10:10 am, Because Eric Null was on vacation