



Garrett County Government Department of Financial Services
Purchasing Division

203 South Fourth Street, Room 206, Oakland, Maryland 21550
garrettcourtymd.gov/financial-services/purchasing

A D D E N D U M 1

DATE: March 20, 2025
TO: All Bidders
FROM: Trevor Butler
Purchasing Agent
RE: Invitation to Bid #25-0327 Garrett County Health Center Boiler Replacement

Please note the following clarification to Invitation to Bid #25-0320 Garrett County Health Center Boiler Replacement resulting from a question received from an interested bidder:

1. In reference to installation of new Boilers & piping should we drain the complete system to relocate the two existing 4" gate valves or leave them in current location and pipe the new boilers to them?

Answer: Pipe the new boilers to the existing 4" valves. The HVAC system is a 2 pipe system, cooling will need to be operational during the boiler change.

Please acknowledge receipt of Addendum 1 by initialing the appropriate section on the Signature to Bids Page of the bid package.