



Garrett County Government Department of Financial Services
Purchasing Division

203 South Fourth Street, Room 206, Oakland, Maryland 21550
garrettcourtymd.gov/financial-services/purchasing

A D D E N D U M 2

DATE: July 1, 2026
TO: All Bidders
FROM: Trevor Butler
Purchasing Agent
RE: Invitation to Bid #26-070BR Garrett County Courthouse Window and Door Replacement

Please note the following clarification to **Invitation to Bid #26-070BR Garrett County Courthouse Window and Door Replacement** resulting from a question received from an interested bidder:

1. Can you also please clarify the specs of the drawings?

- a. An additional attachment has been downloaded to the bid packet under additional documentation
 - i. ALL BIDDERS ARE REQUIRED TO DO THEIR OWN MEASUREMENTS TO ENSURE ACCURACY

2. Does the glass have to be insulated?

- a. Section 3.1 of the packet
 - i. Glass-clad polycarbonate (GCP), polycarbonate laminates, or insulated BR glazing units shall be used as required for energy performance and threat level

3. Does the glaze and color have to match existing glass?

- a. Yes, color must match the existing tinting of the glass

Please acknowledge receipt of Addendum 2 by initialing the appropriate section on the Signature to Bids Page of the bid package.