



Garrett County Government Department of Financial Services  
**Purchasing Division**

203 South Fourth Street, Room 206, Oakland, Maryland 21550  
garrettcourtymd.gov/financial-services/purchasing

---

**A D D E N D U M 4**

---

**DATE:** September 17, 2025  
**TO:** All Bidders  
**FROM:** Trevor Butler  
Purchasing Agent  
**RE:** Invitation to Bid #25-0923 Shallmar Landslide Repair Phase II

Please note the following clarification to Invitation to Bid #25-0923 Shallmar Landslide Repair Phase II resulting from a question received from an interested bidder:

Questions

1. Will the engineer provide us with 5 control points for our GPS and Survey Equipment on the initial setup?

Answer: No, there are two control points provided (coordinates are on Sheet 4 of the drawings). Any additional points will need to be set by the contractor.

2. Does the inspector for the Quality Control Portion need to be a third-party professional engineer? If so, do they have to provide a final report once the job is complete?

Answer:

This is a blanket spec and Section 3.4 is likely not applicable for this procurement as there are no compaction requirements (proctor) or concrete testing. Section 3.3 is applicable for submittals

3. If we put stone on the existing grass access path beyond the stone access road, does it need to be removed and revegetated or can the stone stay?

Answer: The stone can stay.

4. Will we be able to extend days for weather if we have inclement weather and can't work, or will these be included in the contract time?

Answer: Yes, if weather becomes an issue we will work with the contractor on bad weather days.

5. Can rock trucks be used to haul material on the county road to the disposal site?

Answer No, due to weight limits on 3 bridges that would need to be crossed. Triaxles can be used though.