



Garrett County Government Department of Financial Services
Purchasing Division

203 South Fourth Street, Room 206, Oakland, Maryland 21550
garrettcourtymd.gov/financial-services/purchasing

A D D E N D U M 3

DATE: November 22, 2024
TO: All Contractors
FROM: Brian Bowers
Purchasing Agent
RE: Invitation to Bid #24-1205
Wisp Mountain Storage Tank

Please note the following clarification to Invitation to Bid #24-1205 Wisp Mountain Storage Tank resulting from a question from an interested contractor:

1. On Page 12 of the drawings, it shows C-909 (Class 150) pipe. Is this correct or is all the pipe supposed to be C-900?

Answer: The drawing is correct. All pipes shall be C-909 (Class 150) pipe.

Please acknowledge receipt of Addendum 3 by initialing the appropriate section on the *Signature to Bids* page and all other applicable areas of the bid package.